

RFB TO-19-13  
Concrete Pads for Bus Stops Phase 8.3  
Questions & Answers  
December 31, 2018

- Q1. Please confirm the type of concrete mix for the 5” and 4” concrete.  
A1. Use a City sidewalk mix.
- Q2. Please confirm what reinforcement is in the concrete, if any?  
A2. Please see the engineering studies. There is no reinforcement needed in the 4” or 5” concrete.  
Some of the curbing may require wire mesh or other material.

End of Q&A.